

## Propane Checklist for Fair Vendors

### **Propane Container Filled On Site:**

Must be 10' from a source of ignition  
(open flame, motor)

### **Propane Container Not Filled On Site**

Must be 5' from a source of ignition

---

### **All Propane Containers**

1. Must be installed upon a firm, level surface and on a paved surface or solid concrete blocks. 20# cylinders may be set in a milk crate.
2. Must be provided with a means of stabilizing the cylinder to prevent falling over.
3. Must be protected from vehicle damage at all times.
4. Spare propane cylinders must be secured at all times.
5. Propane cylinders must be kept qualified. This qualification runs out 12 years after manufacture. Cylinders must be re-qualified after this date expires or taken out of service.

---

### **Regulators**

1. Regulator vents must be 3' from any source of ignition.
2. Regulators must be supported and protected from damage at all times.

---

### **Appliances**

1. All appliances, owned or rented, must have a listed gas shut off valve within 6' of the appliance. The tank shut off does not qualify.
2. Unlisted outdoor cooking appliances must maintain clearances to combustibles and must not be located under combustible construction. 36" - sides and back. 48" - front.
3. Appliances must be placed on a firm, level foundation. Not earth.
4. Propane lines or hoses must be supported and protected from damage at all times.
5. Propane hoses must be properly marked LP-GAS, 350 PSI Working Pressure or Propane.
6. A qualified fire extinguisher must be present at all times.

Propane & Natural Gas Board  
35 State House Station, Augusta, ME 04333-0035  
Phone: 207-624-8608